



海运
By Sea



中国认可
检验
INSPECTION
CNAS IB0078

运输危险性鉴别报告书

Identification and Classification Report for Transport of Goods

危险物品
(Dangerous Goods)

报告编号:

SEKGZ202412221184WY840001

Issued No:

生效日期:

2025.01.01

Effective Date:

委托单位:

深圳市华美兴泰科技股份有限公司

Applicant:

Hamedata Technology Co., Limited

物品名称:

储能电源 MST-HIE2.5-0800 2560Wh

Name of Goods:

Balcony All-in-one ESS MST-HIE2.5-0800 2560Wh

北京迪捷姆空运技术开发有限公司

Beijing DGM Air Transport Technology Development Co., Ltd.



报告书使用约定

Terms of the Using of the Report

1. 本公司依据委托人（托运人或其代理人）提供的物品及其运输信息，确定物品的危险性并出具此报告书。

The report is issued by DGM China according to the information of the goods and the information of its shipping provided by the applicant (shipper or his agent).

2. 依据鉴别的需要，本公司要求委托人提供真实、完整的样品及资料。

According to the demand of identification and classification, DGM China requires the applicant to provide true and exact sample and data of the goods.

3. 委托人保证申报的物品和/或提供的样品与交运的货物是同一种物质。

The applicant guarantees that the declared goods and/or the sample who provides should be identical with the contents of cargo that is to be transported.

4. 本公司仅对委托方所提供样品的鉴别结果负责。

DGM China is only responsible for the identification and classification of the sample provided by the applicant.

5. 本报告书经主检员、审核人和批准人签字并加盖本公司印章后生效。

This report will be effective only after it is signed by the inspector, checker and approver, and stamped by DGM China.

6. 未经本公司书面批准，不得复制本报告书。

The duplicating of this report is prohibited without the written approval of DGM China.

7. 私自转让、复制、盗用、冒用、涂改、或以任何媒体形式篡改的报告书无效。

The report is invalid when anything of the following happens - illegal transfer, reproduce, embezzlement, imposture, modification or tampering in any media form.

8. 报告书仅在本年度内有效。

This report is only valid within the year.

地址：北京首都机场货运北路天竺综合保税区 BGS 货运楼 249 室 邮编：101300

电话：010-69479673

传真：010-69479621

网址：www.dgmchina.com.cn

E-mail: test@dgmchina.com.cn



项目编号 Item No.		SEKGZ202412221184	签发日期 Issued Date	2024.12.24
鉴别目的 Identification Purpose		是否属于运输危险物品 Dangerous Goods or not restricted	鉴别日期 Identification Date	2024.12.22-2024.12.24
鉴别依据 Identification Criteria		IMDG CODE (Amdt 42-24)		
物品名称 Name of Goods	中文名称 Name of Chinese	储能电源 MST-HIE2.5-0800 2560Wh		
	英文名称 Name of English	Balcony All-in-one ESS MST-HIE2.5-0800 2560Wh		
生产厂家 Manufacturer		湖南普朗克储能科技有限公司 Hunan Planck Esstechnology Co., Ltd.		
物品信息 Nature of Goods		该物品为锂离子电池，灰色，近长方体，尺寸：（304×230×460）mm。 型号/族号：MST-HIE2.5-0800 每包装件中电池或电芯数量：1块 每包装件中的净重：38kg 每一包装件的毛重：41kg 单独包装 （注：单块电池的重量约为38kg。） The goods are lithium ion batteries, gray, almost cuboid, Size: (304×230×460) mm. Model/Group: MST-HIE2.5-0800 Number of batteries or cells per package: 1 pieces Net quantity per package: 38kg Gross weight of each package: 41kg Cells or batteries only		
鉴别结论 Conclusions		危险物品 (Dangerous Goods)		
		UN 编号(UN No.):	UN3480	
		运输专用名称(PSN)	Lithium ion batteries	
		危险性类别(Class or Div.)	9	
		包装等级(PG)	/	
备注 Comment		包装必须达到 II 级包装的性能标准。 Packagings must meet Packing Group II performance standard.		
主检员 Appraiser		张图梁	审核人 Checker	梁生
			批准人 Approver	张图梁
			报告单位（盖章） Stamp	



项目编号 Item No.		SEKGZ202412221184	
物品名称 Name of Goods	中文名称 Name of Chinese	储能电源 MST-HIE2.5-0800 2560Wh	
	英文名称 Name of English	Balcony All-in-one ESS MST-HIE2.5-0800 2560Wh	
鉴别项目名称 Item			检验结果 Inspection Result
该电池额定瓦特小时数为 2560 Wh。 Watt-hour rating of the battery is 2560 Wh.			>100Wh
锂电池已通过 UN38.3 测试。 Each battery is of a type proved to meet the Requirements of each test in the UN MANUAL OF TESTS AND CRITERIA, Part III, sub-section 38.3.			符合 Conform
电池按照规定的质量管理体系进行制造。 Batteries be manufactured under a quality management programme.			符合 Conform
该锂电池不属于召回电池，不属于废弃和回收电池。 The lithium batteries don't belong to batteries returned to the manufacturer for safety reasons, are not waste lithium batteries and not lithium batteries being shipped for recycling or disposal.			符合 Conform
通过包装件 1.2 米跌落试验。 Each package is capable of withstanding a 1.2m drop test in any orientation.			不适用 Not applicable
包装件需要按照特殊规定188的要求进行适当标记。 The package must be appropriately marked according to special provision 188.			不适用 Not applicable
每票托运物品均有随附文件说明： 包装件内装锂离子电池或电芯； 必须小心操作。如包装件破损，有易燃危险性； 包装件破损时应采取的特殊措施，包括检查和必要时的重新包装； 应急电话号码。 Each consignment is accompanied with a document with an indication that: the package contains lithium ion cells or batteries; the package must be handled with care, and that a flammability hazard exists if the package is damaged; special procedures should be followed in the event the package is damaged, to include inspection and repacking if necessary; and a telephone number for additional information.			不适用 Not applicable
/			/
/			/
注意事项 Remarks	每一单电池必须做好防短路措施，并装入坚固外包装内。 Each single battery must be packed in such a way as to prevent short circuits under the normal conditions and packed in strong outer packagings.		

出单：王义



北京迪捷姆空运技术开发有限公司

项目编号: SEKGZ202412221184

物品名称: 储能电源 MST-HIE2.5-0800 2560Wh

储能电源 Balcony All-in-one ESS:



Balcony All-in-One ESS		
Model:	MST-HIE2.5-0800	
Battery	Battery Energy:	2560Wh
	Type:	LiFePO4
	Depth of Discharge:	90%
	Nominal voltage:	51.2V(16S)
	Capacity:	50Ah
PV	Max. Input Voltage:	60 Vdc
	Range of Mppt Voltage:	16-55 Vdc
	Max. Input Current:	4*14.5 Adc
	Max. Short Current:	4*20 Adc
	Nominal Output Voltage:	230 Vac
Grid	Nominal Output Frequency:	50/60 Hz
	Max. Continuous Output Current:	3.48 Aac
	Max. Output Power:	800 VA
	Output Power Factor:	>0.99(Default)
	Protective Class:	I
	Ingress Protection:	IP65
	Operating Ambient Temp	-20-55 °C
Size(L*W*H): 304*230*460mm		



包装件 Package:



锂电池/钠离子电池 UN38.3 试验概要 Test Summary

项目编号: SEKGZ202412221184

单位信息 Company Information					
委托单位 Consignor	深圳市华美兴泰科技股份有限公司 Hamedata Technology Co.,Limited 深圳市坪山区龙田街道竹坑社区规划五路2号长方照明工业厂区厂房A一层A区、 二层、三层、六层、七层、八层/1-3F & 6-8F, BLDG#A, Changfang Industrial Park, No.2 Guihua 5th Road, Pingshan District, Shenzhen				
生产单位 Manufacturer	湖南普朗克储能科技有限公司 Hunan Planck Esstechnology Co., Ltd. 湖南省湘西高新区马鞍山隧道与张社大道交叉口南侧西区产业园标准厂房 Building 12, West Industrial Park, south of the intersection of Ma'anshan Tunnel and Zhangshe Avenue, Xiangxi High-tech Zone, Hunan Province 电话/Tel: 13886062772				
测试单位 Test Lab	广东储能检测技术有限公司 Guangdong ESTL Technology Co., Ltd. 广东省东莞市松山湖园区总部二路9号1栋1单元101、201-208室、4单元201 室和11号1栋2单元101室。/Room 101, 201-208, Unit 1, & Room 201, Unit 4, Building 1, No.9/Room 101, Unit 2, Building 1, No.11, Zongbu 2nd Road, Songshanhu Park, Dongguan, Guangdong, China 电话/Tel: 0769-85075888 邮箱/Mail: gdestl@gtggroup.com 网址/Website: www.gdestl.com				
电池信息 Battery Information					
名称 Name	储能电源 Balcony All-in-one ESS	电池/电芯类别 Battery/Cell Classification		锂离子电池 Li-ion Battery	
型号 Type	MST-HIE2.5-0800	商标 Trademark		/	
额定电压 Normal Voltage	/	额定容量 Rated Capacity		50Ah	
额定能量 Watt-hour rating	2560Wh	外观/Appearance		灰色近长方体 Approximate Gray Cuboid	
质量/Mass	38kg	锂含量/Li Content		不适用 N/A	
测试信息 Test Information					
测试报告编号 Test Report Number	S03A24110592U01901		测试报告签发日期 Date of Test Report	2024-11-25	
测试标准 Edition of UN Manual of Tests and Criteria Used	联合国《试验和标准手册》第八修订版 38.3 节 UNITED NATIONS the "Manual of Test and Criteria" ST/SG/AC.10/11/Rev.8/Section 38.3				
T.1: 高度模拟 Altitude Simulation	通过 Pass	T.2: 温度试验 Thermal Test	通过 Pass	T.3: 振动 Vibration	通过 Pass
T.4: 冲击 Shock	通过 Pass	T.5: 外部短路 External Short Circuit	通过 Pass	T.6: 撞击/挤压 Impact/Crush	通过 Pass
T.7: 过度充电 Overcharge	通过 Pass	T.8: 强制放电 Forced Discharge	通过 Pass	/	
UN38.3.3.1(f)或/or UN38.3.3.2(d)	不适用 N/A		UN38.3.3.1(g)或/or UN38.3.3.2(e)	不适用 N/A	
备注 Note	/				
签名 Signatory 职务 Title	张周梁 检验员		签发日期 Issued Date	2024-12-22 DGM-CHINA	